

Pool Inspection Courtesy Check List

- Display at poolside all ring buoys with safety lines installed.
- Make sure the pool thermometer is installed in pool.
- Display at poolside "Sheppards Safety Hook."
- Make sure the "No Diving" signs are posted.
- Make sure that your "Spine Board", neck brace, & restraining straps are in good shape and on display.
- Make sure that there is a working telephone at poolside for emergency use.
- Make sure Emergency Phone numbers are posted, (Police, Fire, Ambulance & 911).
- Make sure safety line between deep & shallow ends is installed.
If you have underwater lighting make sure that they all work.
- Make sure chemical pool test kit is available for inspection.
- Make sure chemical records sheets are available for review.
- Make sure the accident record sheets are available for review.
- Make sure that all gates leading to the pool area are self-closing and self-locking.
- Make sure that the pool pH is between 7.2pH to 7.8pH.
- Make sure the alkalinity is 60ppm minimum.
- Make sure the Chlorine level is 1.0ppm minimum or the Bromine level is 2.0ppm minimum.
- Make sure the cyanuric acid level in the swimming pool does not exceed one hundred parts per million. Cyanuric acid, if in use, shall be tested on a weekly basis during all parts of the year that the pool or spa is in operation.
- Make sure that the total dissolved solids (TDS) level in the pool does not exceed three thousand parts per million.
- Make sure that all chemicals are stored safely and properly.
- Make sure that all lifeguard chairs are installed.
- Make sure that you have the following documentation for each lifeguard on file for review (Make me photo copies): Life saving certificate/card, first aid certificate/card and CPR certificate/card.
- Make sure that the flow meter(s) are properly installed and working.
- Make sure that the pool filter pressure gauges are installed properly and working.
- Make sure that the recirculation/filtration system is continuous working 24hrs. /day.
- Make sure that all restrooms are clean and well maintained.